

PLANNING COMMISSION 556 Elm Street P.O. Box 370 Chester, VT 05143 (802) 875-2173 office (802) 875-2237 fax pcchair@chestervt.gov www.chestervt.gov

March 20, 2023

DRAFT *** DRAFT *** DRAFT *** DRAFT *** DRAFT *** DRAFT

Brian J. Sullivan MSK Attorneys 275 College Street, P.O. Box 4485 Burlington, VT 05406-4485

RE: Industrial Wireless Technologies application for Chester wireless tower

Dear Brian Sullivan:

The Chester Planning Commission met on March 20, 2023, and reviewed your pre-application notice dated February 15, 2023, which was received on February 21, 2023, regarding a proposed wireless tower off Whitmore Brook Road. The Planning Commission has the following comments:

- The tower is proposed to be 183 feet tall, about 108 feet above the average tree height. We have been informed that a balloon test has been conducted and a report on aesthetics is being prepared. This tower seems rather tall, and the Planning Commission would welcome an opportunity to review the report on aesthetics before an application is submitted.
- 2. Chester recently experienced a prolonged power outage in which cell phone coverage failed after about 8 hours. What would be the feasibility of this tower being able to operate for 24 to 48 hours after a power outage through battery backup, generator backup, or both? Also, what would be the feasibility of connecting to the terminal pole of the 3-phase power line at the so-called north quarry on VT-103 as a more reliable source of power?

We look forward to your response to these comments.

Sincerely,

Hugh Quinn Planning Commission Chair